

Qualified Wood I-Joists With Low Formaldehyde Emissions

PR-E730
Revised February 23, 2017

Product: Wood I-Joists Qualified for Low Formaldehyde Emissions

1. Basis of the product report:
 - APA Custom Product Specification E-730
 - Test method follows the principles of ISO 12460-4, Wood-Based Panels -- Determination of Formaldehyde Release, Part 4: Desiccator Method, and AS/NZS 4357.4:2005, Structural Laminated Veneer Lumber, Part 4: Determination of Formaldehyde Emissions
 - ASTM D5055-13, D5055-09, and D5055-05 recognized by the 2015 IBC and IRC, 2012 IBC and IRC, and 2009 IBC and IRC, respectively
 - APA Reports (see Table 2) and other qualification data
2. Product description:
Wood I-joists are made with either solid sawn or LVL flanges and OSB webs of various species and classifications in accordance with the in-plant manufacturing standard approved by APA. Wood I-joists are available in a variety of depths and sizes.
3. Formaldehyde emission level:
The G-5 rating is a formaldehyde emission level as defined in Table 1. Wood I-Joists have been qualified for low formaldehyde emissions following the principles of ISO 12460-4 and AS/NZS 4357.4:2005, and the performance requirements of ASTM D 5055. Wood I-joists meeting the formaldehyde emission level specified in Table 1 in accordance with the APA Custom Product Specification E-730 are listed in Table 2.

Table 1. Upper formaldehyde emission level for G-5 rating following the principles of ISO 12460-4 and AS/NZS 4357.4:2005^(a)

Average	0.20 mg/ℓ
Individual specimen	0.30 mg/ℓ

^(a) I-joists meeting ASTM D 5055 are not within the scope of the CARB rule or HUD regulations. The tabulated formaldehyde emission level in the G-5 standard is more stringent than the E₀ of AS/NZS 4357.4:2005 and F☆☆☆☆ of JAS Standard for Laminated Veneer Lumber, MAFF Notification 701.

4. Limitations:
 - a) Wood I-joists shall be designed and installed in accordance with the applicable provisions of the code and the recommendations provided by the manufacturers and APA Design/Construction Guide: *Engineered Wood Construction Guide*, Form E30 (www.apawood.org/resource-library).
 - b) Wood I-joists are limited to dry service conditions that result in the average equilibrium moisture content of sawn lumber of less than 16 percent.
 - c) Wood I-joists are produced by the manufacturing facilities shown in Table 2 under a quality assurance program audited by APA in accordance with the APA Custom Product Specification E-730.
 - d) This report is subject to re-examination in one year.
5. Identification:
Wood I-joists are identified by a label bearing the manufacturer's name and/or trademark, the APA assigned plant number, the I-joist series and depth, the APA logo, the product report number PR-E730, and the formaldehyde emission rating G-5.

Table 2. Qualified Manufacturing Facilities for Low Formaldehyde Emission

Manufacturer	Location	Applicable Joist Series ^(a)	Mill Number	APA Test Report
Anthony Eacom, Inc.	Sault Ste. Marie, ON	PJI 40, PJI 60 , PJI 80, and PJI 90	1058	T2011Q-17
Boise Cascade Company	1) Lena, LA 2) White City, OR	BCI 40, 400, 4000, BCI 40S, 400S, 4000S, BCI 45, 450, 4500, BCI 45S, 450S, 4500S, BCI 50, 500, 5000, BCI 50S, 500S, 5000S, BCI60, 600, 6000, BCI 60S, 600S, 6000S, BCI 65, 650, 6500, BCI 65S, 650, 6500, BCI 90, 900, 9000, BCI 90S, 900S, 9000S, BCI 90e	1) 1105 2) 1109	T2015P-28
Boise Cascade Company	St. Jacques, NB	AJS-5, AJS-10, AJS-20, AJS-20v, AJS-110, AJS-140, AJS-150, AJS-150v, AJS-160, AJS-170, AJS-180, AJS-190, AJS-25, AJS-25v, AJS-30, BCI 90e	1108	T2015P-28
Nordic Structures	Chibougamau, QC	NI 20, NI 40, NI 40x, NI 60, NI 70, NI 80, NI 80x, NI 90, and NI 90x	1052	T2013Q-11
Pacific Woodtech Corporation	Burlington, WA	PWI 20, PWI 30, PWI 40, PWI 45, PWI 47, PWI 50, PWI 60, PWI 70, PWI 80, PWI 77, PWI 77w, PWI 90, SJ 40, SJ 44, SJ 51, SJ 58, SJ 70, SJ 90, SJ 40 H2S, SJ 44 H2S, SJ 51 H2S, SJ 58 H2S, SJ 70 H2S, and SJ 90 H2S	1048	T2010Q-09
Roseburg Forest Products Company	Riddle, OR	RFPI 20, RFPI 40, RFPI 400, RFPI 70, RFPI 90, RFPI 700, and RFPI 900	1053	T2012Q-43

^(a) I-joist series listed in this table are recognized in an APA Product Report or ICC-ES evaluation report, or are available from the manufacturer.

APA – The Engineered Wood Association is an approved national standards developer accredited by American National Standards Institute (ANSI). APA publishes ANSI standards and Voluntary Product Standards for wood structural panels and engineered wood products. APA is an accredited certification body under ISO/IEC 17065 by Standards Council of Canada (SCC), an accredited inspection agency under ISO/IEC 17020 by International Code Council (ICC) International Accreditation Service (IAS), and an accredited testing organization under ISO/IEC 17025 by IAS. APA is also an approved Product Certification Agency, Testing Laboratory, Quality Assurance Entity, and Validation Entity by the State of Florida, and an approved testing laboratory by City of Los Angeles.

**APA – THE ENGINEERED WOOD ASSOCIATION
HEADQUARTERS**

7011 So. 19th St. ▪ Tacoma, Washington 98466
Phone: (253) 565-6600 ▪ Fax: (253) 565-7265 ▪ Internet Address: www.apawood.org

PRODUCT SUPPORT HELP DESK
(253) 620-7400 ▪ *E-mail Address:* help@apawood.org

DISCLAIMER

APA Product Report® is a trademark of *APA – The Engineered Wood Association*, Tacoma, Washington. The information contained herein is based on the product evaluation in accordance with the references noted in this report. Neither APA, nor its members make any warranty, expressed or implied, or assume any legal liability or responsibility for the use, application of, and/or reference to opinions, findings, conclusions, or recommendations included in this report. Consult your local jurisdiction or design professional to assure compliance with code, construction, and performance requirements. Because APA has no control over quality of workmanship or the conditions under which engineered wood products are used, it cannot accept responsibility for product performance or designs as actually constructed.